



# ST. CLAIR COUNTY HEALTH DEPARTMENT

19 PUBLIC SQUARE, SUITE 150  
BELLEVILLE, ILLINOIS 62220-1624  
www.health.co.st-clair.il.us



## INSTRUCTIONS FOR AFTER BOIL ORDER HAS BEEN LIFTED

Kelly Wood, M.D.  
President, Board of Health

Barbara A. Hohlt, B.S., L.E.H.P., R.E.H.S.  
Executive Director

Administrative/Fiscal  
618.233.7703  
618.222.1630 fax

### Infectious Disease Prevention

- Communicable Disease  
618.233.6175  
618.233.9356 fax
- Southwestern Illinois  
HIV Care Connect  
618.825.4501  
618.825.4585 fax
- Emergency Preparedness  
618.233.7703  
618.233.7713 fax

### Personal Health

- Maternal-Child Health Programs  
618.233.6170  
618.236.0821 fax
- Breast and Cervical Cancer  
WISEWOMAN  
618.233.7703  
618.233.7713 fax

### Environmental Health

- 618.233.7769
- 618.236.0676 fax

1. Run all water lines including the fill points for soft drink machines for 1 minute to flush non potable water from the system.
2. Clean and sanitize all fixtures, sinks, and equipment connected to water lines according to manufacturer's directions.
3. Run the dishwasher empty through three complete cycles to flush the water lines and assure the dishwasher is cleaned and sanitized internally before washing dishes and utensils in it.
4. Discard all ice in ice machines, clean and sanitize the interior surfaces. Run the ice through three cycles and discard the ice with each cycle.
5. Replace all ice machine filters and beverage dispenser filters and flush all water lines for 10 to 15 minutes.
6. Drain the hot water tanks to remove sediment.
7. Remove and clean faucet aeration screens.

Thank you for your cooperation with Boil Order Procedures

